

[My Secure Services](#)[Account Management](#)[Help](#)[About SecureAccess](#)[Logout](#)

Hello orzech.emily@epa.gov

My Services

Add a New Service

Service	Agency	Description	User Status	Action
Underground Storage Tank Tracking System	Department of Ecology	Underground Storage Tank tracking system. This is a rewrite of an existing system.	Active	Remove

[My Secure Services](#) | [Account Management](#) | [About SecureAccess](#) | [Help](#) | [Logout](#) | [Privacy Notice](#)

Copyright 2004-2013 © Washington State Department of Information Services -- All Rights Reserved

Address: 3613 4TH AVE S

City: Seattle

UBI#: 178-048-953 001 0085

F/S ID: 2171 Documents

Site

Tanks (3)

Services (4)

Inspections (4)

Enforcements (1)

Affiliations (8)

Financial

Map

Site Name: SOUTH SERVICE CENTER

Site Address

Street: 3613 4TH AVE S

City/County: Seattle, King

Zip: 98134-2208

Site Phone: (206) 386-4577

Mailing Address (View History)

Street: ATTN: BILL DEVEREAUX

PO BOX 34023

City: SEATTLE

State: WA

Zip: 98124-4023

Comments:

Comments (3)

Inspection with AI on 3/20
3/5/201311/3/05 GG-NWRO See ER
dispenser island found dur
SABYR REQUESTED WAIVE
WILL START REMOVAL/ IN
30 DAY TO BE MAILED TO
TANKS AS REMOVED CLOS
ENTERED INFO FROM PRIM
STANDARDS. KGB/37/23/12 CR Jennifer Kindre
Jennifer.Kindred@seattle.g
11/5/10aa- 2005 tank Glas
Corning. 4/7/06 aa- rec'd p
tanks six, four, five, three. 4
TANK INSTALLATION. 3/15
SEVEN are operational. 3/1
WANDA FOR ONE NEW TA
DOL. 3/1/06 TD HQ MARKI
FOUR, FIVE AND SIX REMC
REQUEST VIA PARTIAL REP
REMOVED. IT IS TO BE REP
TANKS FOUR, FIVE AND S

UBI#: 178-048-953 001 0085

Responsible Unit: NORTHWEST

Owner Type: Municipal (City,Town,PUD,Port)

Entered Date: Unknown

Abandoned Site: No

Current and Historical Tags

Tag Number	Issued By	Issued Date	Status	Status Date	Comments
A0269	HICKEY, JOE	9/23/1998	Issued		

Edit

Audit

Mailing Address (View History)

Street: ATTN: BILL DEVEREAUX

PO BOX 34023

City: SEATTLE**State:** WA**Zip:** 98124-4023**Comments:**

Comments (3)

11/3/05 GG-NWRO See ERTS 551466 re pcs under dispenser island found during upgrade. /// 10/4/05 AA-SABYR REQUESTED WAIVER TO 30 DAY WAIT TIME; WILL START REMOVAL/ INSTALL 10/24/05; GRANTED; 30 DAY TO BE MAILED TO HQ. 4/14/98 JMS- ADDED 4 TANKS AS REMOVED CLOSED 1-17-98. 3/4/98 CM- RE-ENTERED INFO FROM PRIME. ALL TANKS MEET TAG STANDARDS. KGB/3

7/23/12 CR Jennifer Kindred (206) 684-3499
Jennifer.Kindred@seattle.gov contact
11/5/10aa- 2005 tank Glasteel, other two Owens Corning. 4/7/06 aa- rec'd perm closure checklist for tanks six, four, five, three. 4/7/06 TD HQ REC'D NEW TANK INSTALLATION. 3/15/06 AA- Tanks ONE, TWO, & SEVEN are operational. 3/1/06 TD HQ SENT E MAIL TO WANDA FOR ONE NEW TANK TO BE REGISTERED W/ DOL. 3/1/06 TD HQ MARKED TANKS ONE, TWO, THREE, FOUR, FIVE AND SIX REMOVED AS PER JOHN BAILS REQUEST VIA PARTIAL REPORT GIVEN. TANK 'SIX' IS REMOVED. IT IS TO BE REPLACED WITH NEW TANK. TANK 'FOUR', 'FIVE' AND 'THREE' ARE REMOVED & WILL NOT BE REPLACED. 30 DAY NOTICE MAY HAVE BEEN LACKING THESE ID #S. INFO FROM MIKE WEBB OF GARY STRUTHERS. REFER TO ERTS 551466 FOR MORE INFO. INITIAL RESULTS DO NOT INDICATE A NEW RELEASE. WAITING FOR CLEANUP REPORT TO DETERMINE IF NEW LISTING REQUIRED. [JMB,11/8/05]

Responsible Unit: NORTHWEST**Entered Date:** Unknown**Abandoned Site:** No

Issued Date ▾ Status ▾ Status Date ▾ Comments ▾

/23/1998

Issued

Site

Tanks (3)

Services (4)

Inspections (4)

Enforcements (1)

Affiliations (8)

Financial

Map

Select a tank to view or edit its information☐ Show all tanks (16 total)

EditAddAudit

Tank Name	Status	Install Date
SEVEN	Operational	12/12/2005
ONE	Operational	3/1/1989
TWO	Operational	3/1/1989

Tank Name: ONE

Install Date: 3/1/1989

Status: Operational

Upgrade Date: 3/1/1989

Status Date: 8/6/1996

Perm. Closure Date: 10/26/2005

Tank

Material: C Fiberglass Reinforced Plastic

Tightness Test:

Construction: B Double Wall Tank

Spill Prevention: A Spill Bucket/Spill Box

Corrosion Prot: D Corrosion Resistant

Overfill Prevention: B Overfill Alarm

Manifolded Tank:

Tot Actual Capacity: 4000

1st Rel Detect: C Automatic Tank Gauging

Capacity Range: C 2,001 to 4,999 Gallons

Compartments

Compartment#	Substance Stored	Substance Use	Capacity (Gallons)
1	B Unleaded Gasoline	A Motor Fuel for Vehicles	4000

Piping

Material: C Fiberglass

Construction: B Double Wall Pipe

Corrosion Prot: C Corrosion Resistant

SFC at Tank:

SFC at Disp/Pump:

1st Rel Detect: G Interstitial Monitoring (or Su

2nd Rel Detect:

Pumping System: B Safe Suction (Pump Check V

Endorsement (View History)

Expiration Date: 7/31/2014

Status: A Active

Status Date: 7/8/2013

https://secureaccess.wa.gov/ecy/ust/

7/29/2013

Site **Tanks (3)** Services (4) Inspections (4) Enforcements (1) Affiliations (8) Financial Map

Select a tank to view or edit its information

☐ Show all tanks (16 total)

Edit

Add

Audit

Tank Name	Status	Install Date
SEVEN	Operational	12/12/2005
ONE	Operational	3/1/1989
TWO	Operational	3/1/1989

Tank Name: TWO

Install Date: 3/1/1989

Status: Operational

Upgrade Date: 3/1/1989

Status Date: 8/6/1996

Perm. Closure Date: 10/26/2005

Tank

Material: C Fiberglass Reinforced Plasti
Construction: B Double Wall Tank
Corrosion Prot: D Corrosion Resistant
Manifolded Tank:
1st Rel Detect: C Automatic Tank Gauging
Tightness Test:
Spill Prevention: A Spill Bucket/Spill Box
Overfill Prevention: B Overfill Alarm
Tot Actual Capacity: 4000
Capacity Range: C 2,001 to 4,999 Gallons

Compartments

Compartment#	Substance Stored	Substance Use	Capacity (Gallons)
1	B Unleaded Gasoline	A Motor Fuel for Vehicles	4000

Piping

Material: C Fiberglass
Construction: B Double Wall Pipe
Corrosion Prot: C Corrosion Resistant
SFC at Tank:
SFC at Disp/Pump:
1st Rel Detect: G Interstitial Monitoring (or Su
2nd Rel Detect:
Pumping System: B Safe Suction (Pump Check V

Endorsement (View History)

Expiration Date: 7/31/2014

Status: A Active

Status Date: 7/8/2013

Site **Tanks (3)** Services (4) Inspections (4) Enforcements (1) Affiliations (8) Financial Map

Select a tank to view or edit its information

☐ Show all tanks (16 total)

Edit

Add

Audit

Tank Name	Status	Install Date
SEVEN	Operational	12/12/2005
ONE	Operational	3/1/1989
TWO	Operational	3/1/1989

Tank Name: SEVEN

Install Date: 12/12/2005

Status: Operational

Upgrade Date:

Status Date: 12/12/2005

Perm. Closure Date:

Tank

Material: D Steel Clad with Corrosion F

Tightness Test:

Construction: B Double Wall Tank

Spill Prevention: A Spill Bucket/Spill Box

Corrosion Prot: D Corrosion Resistant

Overfill Prevention: B Overfill Alarm

Manifolded Tank:

Tot Actual Capacity: 4000

1st Rel Detect: F Interstitial Monitoring

Capacity Range: C 2,001 to 4,999 Gallons

Piping

Material: C Fiberglass

Construction: B Double Wall Pipe

Corrosion Prot: C Corrosion Resistant

SFC at Tank:

SFC at Disp/Pump:

1st Rel Detect: D Safe Suction (No Leak Detec

2nd Rel Detect: G Interstitial Monitoring (or Su

Pumping System: B Safe Suction (Pump Check V

Compartments

Compartment#	Substance Stored	Substance Use	Capacity (Gallons)
1	D Diesel	A Motor Fuel for Vehicles	4000

Endorsement [\(View History\)](#)

Expiration Date: 7/31/2014

Status: A Active

Status Date: 7/8/2013

[Home](#)

Site Name: SOUTH SERVICE CENTER **UST ID:** 8827 **Region:** NW **County:** King
Address: 3613 4TH AVE S **City:** Seattle **UBI#:** 178-048-953 001 0085 **F/S ID:** 2171 Documents

ISIS
LUST (1)
VCP (0)

[Site](#) [Tanks \(3\)](#) [Services \(4\)](#) [Inspections \(4\)](#) **[Enforcements \(1\)](#)** [Affiliations \(8\)](#) [Financial](#) [Map](#)

Select an enforcement to view or edit its information

[Edit](#)[Add](#)[Audit](#)

Enforcement Date ▼	Inspector	Enforcement Type ▼
3/20/2013	IMKE, ANDREW	Notice of Non Compliance

Enforcement Date: 3/20/2013

Ticket #:

Enforcement Inspector: IMKE, ANDREW

ECY Docket#:

Enforcement Type: Notice of Non Compliance

Penalty (\$):

[View](#) **Affiliation:** City Of Seattle

Settlement (\$):

Comments (1)

03202013 AI - 03182013 Annual Testing paperwork not on Site, but was present prior to close of inspection.
4/16/2013 3:35:29 PM by IMKE, ANDREW

Violations

* Violation/Field Citation Number ▼	Compliance Due Date ▼	Resolved Date ▼
* 173-360-210(3)	4/1/2013	3/20/2013